

Certification of Runtime Performance



Customer Information



Report Date: 2/21/2018

Standards

Test Load 1200 watts at 120 volt 90 minutes Minimum Runtime

Certification Summary

Certified Test Load 1200 watts, 120volt, Resistive Load
Avg Test Runtime 132 minutes
Minimum Standard **PASSED**
Depreciated Standard **PASSED** (passes at 25% depreciated capacity)
Overload Standard **PASSED** (passes at 25% over test load wattage)

Uninterruptible Power Supply System

System Name	APC 2000va Smart UPS with two extended run unit and bypass unit		
UPS Manufacturer	Schnieder Electric	Batteries	Sealed Lead Acid 12v 5.0 ah
UPS Model #	SMX2000RMLV2U	Serial #	QS1741028388
Extended Run Unit 1	SMX120RMBP2U	Serial #	QS1745528852
Extended Run Unit 2	SMX120RMBP2U	Serial #	QS1745525163
Extended Run Unit 3	not present	Serial #	
		Battery Date	Dec-17
		Battery Date	Dec-17
		Battery Date	Dec-17
		Battery Date	

Test Summaries

Test Type 1: Internal Drain test using defined load and unit's own runtime calculator and Netcard
Internal Device APC Network Management card AP9631 SN# 12566999696
Run 1 Results 132 Test Date 2/28/2018
Run 2 Results 132 Test Date 2/28/2018

Test Type 2: Physical Drain test using defined load until expiration
Run 1 Results 132 Test Date 2/28/2018

Test Type 3: Depreciated Drain test with lab bench batteries fully charged from 2016 to simulate 1 yr old batteries
Run 1 Results 107 Test Date 2/28/2018

Test Type 4: Overload Drain test with load at 120% of test load (1440watts) to simulate overload conditions
Run 1 Results 107 Test Date 2/28/2018

Manufacturer's Runtime Assertion 107 FileInfo

Load Summary (2) 600watt PHC Edison Base Cone Heaters EBCH-120/600
Test File Name EDGE1K2018 Test Tech Name Robert Durham

Best Practices Implementation

Maintenance Bypass Present - YES Remote Monitoring/management - YES
3rd Part Service Contract - NO Field restrictions

Test Limitations

Results are confirm at the time of testing. Over the duration of a year, battery capacities diminish because of number of factors.
Tests performed in lab environment under controlled conditions. Actual field conditions, wiring, and equipment may cause variations.
System should be inspected quarterly and batteries shall be kept in 70 degree environment for optimal performance
All measurements taken with new, fully charged batteries, with no electrical input and balanced resistive load (PF = 1.0) output.